

Specification R 454B

	unit	min.	max.	test method
purity	%-wt	99,5		gaschromatography

composition

R 1234yf	%-wt	30,1	32,1	gaschromatography
R 32	%-wt	67,9	69,9	gaschromatography

impurities

water	mg/kg (ppm)		10	moisture analyser Al ₂ O ₃ -cell
high boiling residue	%-wt		0,01	controlled total evaporation
acidity	mg/kg		0,1	titration
non-conden- sable gases	%-vol		1,5	gaschromatography
appearance	clear, colourless, liquified gas			visuell inspection