

Specification TEGAN® 744

R 744, Carbon dioxide as refrigerant, carbon dioxide 4.5

	unit	min.	max.	test method
purity	%-wt	99,995		gaschromatography
impurities				
water	mg/kg (ppm)		5	moisture analysator Al ₂ O ₃ -cell
particulates/solids	clear, colourless, liquified gas			visuell inspection

Version 09/2024